



VOID FOR USE OF SERVICES ETC

100x50 TOP PLATE MUST USE WASHER

100

WINDOW HEAD GARAGE DOOR BEAM TO ENG. DETAIL

14MM GAL. BROOKER ROD 400mm LONG INSERTED INTO WET CONCRETE @ 750mm CTS OR TO ENG. DETAIL

BROOKER ROD TO BE 100mm ABOVE CONCRETE WALL. NUT & WASHER MUST BE USED

TYPICAL REQUIREMENT FOR WALL @ 2.5m HIGH USE Y-12 BARS @ 250mm HORIZONTAL AND Y-12 @ 375mm VERTICAL WITH ONE EXTRA VERTICAL BAR AT OPENING REVEALS AND EXTRA BARS OVER GARAGE DOORS & WINDOW OPENINGS TO ENGINEER'S DETAIL

RENDER OUTSIDE

GYPROCK INSIDE

RECOMMENDED CONCRETE MIX IS 20 mpa 125mm SLUMP 10mm TO 12mm AGGREGATE PUMP MIX AND DELIVERED WITH 50mm PUMP HOSE. 50% OF WALL HEIGHT TO BE PLACED AT A TIME

Y-12 DOWEL BARS @ 375mm CTS 600mm LONG WITH 100mm DRILLED & GROUTED INTO SLAB ALL TO ENG.DETAIL

65x25x0.6 CHANNEL FIXED DOWN TO SLAB @ 500mm CTS (INSIDE ONLY)

RC SLAB & FOOTINGS TO ENGINEER'S DETAIL

100

**EZY-BLOCK[®] WALL DETAILS
SUBJECT TO ENGINEER'S REQUIREMENTS**